



浙江省泵阀产品质量检验中心
 Quality Inspecting Center of Pump and Valve Products of Zhejiang Province
 国家阀门质量监督检验中心(浙江)
 National Quality Supervision and Inspection Center of Valve Products(Zhejiang)

特种设备型式试验证书

Special Equipment Type Test Certificate

(压力管道元件)

Pressure Piping Components

证书编号 Certificate No: TSX71004820150086

制造单位: **Manufacturer** MIL Controls Limited

单位地址: **Address** Meladoor, Annamanada, Pin -680741, Thrissur
 Dist, Kerala, India.

设备类型: **Equipment type** 压力管道阀门
 Pressure piping valve

产品名称: **Product** 电动调节阀(金属阀门)
 Electric control valve(metal valves)

产品型号: **Model** MIL control valves-CL2500 NPS12 (PN420 DN300)
 MIL control valves-CL3100 NPS4 (PN530 DN100)

型式试验报告编号: **Type test report No** TS201504036
 TS201504037

经型式试验, 确认符合 TSG D7002-2006 《压力管道元件型式试验规则》的要求。本证覆盖以下型号规格的产品:

The products meet TSG D7002-2006 《Pressure Piping Components Type Test Regulation》 by passing the type test. This certificate is covering these products as following:

公称压力≤PN420(CL2500)时, 公称尺寸≤DN400(NPS16); 适用温度-29℃~593℃;

If nominal pressure≤PN420(CL2500), nominal dimension≤DN400(NPS16). The allowable working temperature is -29℃~593℃.

公称压力≤PN530(CL3100)时, 公称尺寸≤DN200(NPS8); 适用温度-29℃~593℃。

If nominal pressure≤PN530(CL3100), nominal dimension≤DN200(NPS8). The allowable working temperature is -29℃~593℃.

浙江省泵阀产品质量检验中心
 Quality Inspection Center of Pump and Valve Products of Zhejiang Province
 国家阀门质量监督检验中心(浙江)
 National Quality Supervision and Inspection Center of Valve Products(Zhejiang)

2015年07月29日

